



NOTES:

1. Customer facilities shall comply with the National Electrical Code and authorities having jurisdiction.
2. All conduit connections to be raintight.
3. Physical location of pole and any guying (if needed) will be approved by CECC
4. Additional pole height may be required to maintain proper clearance.
5. Customer provides and installs service entrance wires, size #6 copper A minimum of 18" of each conductor shall extend beyond the weatherhead. All wires should be same size. NEC 250.56(B).
6. Customer Installed minimum 1/2" galvanized eye bolt with 2" x 2" square washer recommended.

Call before you dig 1-800-482-8998

In location with underground facilities, the Customer shall notify Arkansas One Call and shall have One Call locate all underground facilities before digging. It shall be the responsibility of the Customer to stay clear of all underground facilities.

NEC = National Electric Code
Current Code Requirement

CRAIGHEAD ELECTRIC COOPERATIVE	
TEMPORARY SERVICE FROM AN OVERHEAD SOURCE	
APPROVED BY: KB	DATE: 6-16-06
CHECKED BY: WG	SCALE: none
DRAWN BY: mbarnes	
	DWG NO.: 1101